Safety Data Sheet



0.1% He, 0.1% H2, 0.5% C2H6, 5% CO2, 5% N2, 0.5% O2 in CH4

Date of first issue: 03/04/2013 Revised date: 10/10/2016 Supersedes: 03/04/2013 Version: 2.0

SDS reference: AL702

Danger



SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

SDS no : AL702

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use

Test gas/Calibration gas

Laboratory use

Contact supplier for more information on uses

Uses advised against : Consumer use

1.3. Details of the supplier of the safety data sheet

Company identification : Air Liquide Australia Limited

Level 9 / 380 St. Kilda Road 3004 Melbourne VIC Australia

+61 3 9697 9888

ALAEnquiries@AirLiquide.com

1.4. Emergency telephone number

Emergency telephone number : 1800 812 588

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification according to WHS Regulation

Physical hazards Flammable gases, Category 1 H220

Gases under pressure: Compressed gas H280

2.2. Label elements

Classification according to WHS Regulation

Hazard pictograms :





GHS04

GHS02

Signal word : Danger

Hazard statements : H220 - Extremely flammable gas.

H280 - Contains gas under pressure; may explode if heated.

Precautionary statements

Air Liquide Australia Limited EN (English) SDS Ref.: AL702 1/9
Level 9 / 380 St. Kilda Road 3004



SDS Ref.: AL702

- Prevention: P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No

smoking

- Response : P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely

P381 - Eliminate all ignition sources if safe to do so

- Storage : P403 - Store in a well-ventilated place

2.3. Other hazards

: None

SECTION 3: Composition/information on ingredients

3.1. Substance : Not applicable

3.2. Mixture

Name	Product identifier	%	Classification according to WHS Regulation	
Methane	(CAS No) 74-82-8 (EC no) 200-812-7 (EC index no) 601-001-00-4 (REACH-no) *1	Balance	Flam. Gas 1, H220 Press. Gas (Comp.), H280	
Carbon dioxide	(CAS No) 124-38-9 (EC no) 204-696-9 (EC index no) (REACH-no) *1		Press. Gas (Liq.), H280	
Nitrogen	(CAS No) 7727-37-9 (EC no) 231-783-9 (EC index no) (REACH-no) *1	<= 5	Press. Gas (Comp.), H280	
Ethane	(CAS No) 74-84-0 (EC no) 200-814-8 (EC index no) 601-002-00-X (REACH-no) *2	<= 0.5	Flam. Gas 1, H220 Press. Gas (Comp.), H280	
Oxygen	(CAS No) 7782-44-7 (EC no) 231-956-9 (EC index no) 008-001-00-8 (REACH-no) *1	(CAS No) 7782-44-7		
Hydrogen	(CAS No) 1333-74-0 (EC no) 215-605-7 (EC index no) 001-001-00-9 (REACH-no) *1	<= 0.1	<= 0.1 Flam. Gas 1, H220 Press. Gas (Comp.), H280	
Helium	(CAS No) 7440-59-7 (EC no) 231-168-5 (EC index no) (REACH-no) *1	<= 0.1	Press. Gas (Comp.), H280	

Full text of R- and H-statements: see section 16

Contains no other components or impurities which will influence the classification of the product.

SECTION 4: First aid measures

4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped

SDS Ref.: AL702

Skin contact
 Eye contact
 Adverse effects not expected from this product
 Adverse effects not expected from this product

- Ingestion : Ingestion is not considered a potential route of exposure

4.2. Most important symptoms and effects, both acute and delayed

^{*1:} Listed in Annex IV / V REACH, exempted from registration.

^{*2:} Registration deadline not expired.

^{*3:} Registration not required: Substance manufactured or imported < 1t/y.



SDS Ref.: AL702

 In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/consciousness. Victim may not be aware of asphyxiation

Refer to section 11

4.3. Indication of any immediate medical attention and special treatment needed

: None

SECTION 5: Firefighting measures

5.1. Extinguishing media

Suitable extinguishing media : Water spray or fogUnsuitable extinguishing media : Carbon dioxide

Do not use water jet to extinguish

5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode

Hazardous combustion products : Nitrogen oxides

5.3. Advice for fire-fighters

Specific methods : Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat

radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering sewers and

drainage systems

If possible, stop flow of product

Use water spray or fog to knock down fire fumes if possible

Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-

ignition may occur. Extinguish any other fire

Move containers away from the fire area if this can be done without risk

Special protective equipment for fire fighters

: In confined space use self-contained breathing apparatus

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire

fighters

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask

Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves for

SDS Ref.: AL702

firefighters

Hazchemcode : 2SE

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

: Try to stop release

Evacuate area

Consider the risk of potentially explosive atmospheres

Eliminate ignition sources Ensure adequate air ventilation

Act in accordance with local emergency plan

Stay upwind

6.2. Environmental precautions

: Try to stop release

6.3. Methods and material for containment and cleaning up

: Ventilate area

6.4. Reference to other sections

: See also sections 8 and 13

EN (English)

3/9



SDS Ref.: AL702

SECTION 7: Handling and storage

7.1. Precautions for safe handling

Safe use of the product

: The substance must be handled in accordance with good industrial hygiene and safety procedures

Only experienced and properly instructed persons should handle gases under pressure

Consider pressure relief device(s) in gas installations

Ensure the complete gas system was (or is regularily) checked for leaks before use

Do not smoke while handling product

Use only properly specified equipment which is suitable for this product, its supply pressure and

temperature. Contact your gas supplier if in doubt

Assess the risk of potentially explosive atmospheres and the need for explosion-proof

equipment

Purge air from system before introducing gas

Take precautionary measures against static discharge

Keep away from ignition sources (including static discharges)

Consider the use of only non-sparking tools

Do not breathe gas

Avoid release of product into atmosphere.

Safe handling of the gas receptacle

: Refer to supplier's container handling instructions

Do not allow backfeed into the container

Protect cylinders from physical damage; do not drag, roll, slide or drop

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed

to transport cylinders

Leave valve protection caps in place until the container has been secured against either a wall

or bench or placed in a container stand and is ready for use

If user experiences any difficulty operating cylinder valve discontinue use and contact supplier

Never attempt to repair or modify container valves or safety relief devices

Damaged valves should be reported immediately to the supplier

Keep container valve outlets clean and free from contaminants particularly oil and water Replace valve outlet caps or plugs and container caps where supplied as soon as container is

disconnected from equipment

Close container valve after each use and when empty, even if still connected to equipment

Never attempt to transfer gases from one cylinder/container to another

Never use direct flame or electrical heating devices to raise the pressure of a container Do not remove or deface labels provided by the supplier for the identification of the cylinder contents

Containers should be stored in the vertical position and properly secured to prevent them from falling over.

7.2. Conditions for safe storage, including any incompatibilities

: Observe all regulations and local requirements regarding storage of containers

Containers should not be stored in conditions likely to encourage corrosion

Container valve guards or caps should be in place

Containers should be stored in the vertical position and properly secured to prevent them from

falling over

Stored containers should be periodically checked for general condition and leakage

Keep container below 50°C in a well ventilated place

Store containers in location free from fire risk and away from sources of heat and ignition

Keep away from combustible materials

Segregate from oxidant gases and other oxidants in store

All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.

7.3. Specific end use(s)

: None.

SECTION 8: Exposure controls/personal protection

8.1. Control parameters



SDS Ref.: AL702

0.1% He, 0.1% H2, 0.5%	6 C2H6, 5% CO2, 5% N2, 0.5% O2 in CH4	
OEL: Occupational Exp	osure Limits	
Australia	TWA (mg/m³)	9000 mg/m³ Carbon dioxide
	TWA (ppm)	5000 ppm Carbon dioxide
	STEL (mg/m³)	54000 mg/m³ Carbon dioxide
	STEL (ppm)	30000 ppm Carbon dioxide
Carbon dioxide (124-3	8-9)	
OEL: Occupational Exp	osure Limits	
United Kingdom	WEL - LTEL - UK [mg/m³]	9150 mg/m³
	WEL - LTEL - UK [ppm]	5000 ppm
	WEL - STEL - UK [mg/m³]	27400 mg/m ³
	WEL - STEL - UK [ppm]	15000 ppm

DNEL (Derived-No Effect Level) : No data available.

PNEC (Predicted No-Effect Concentration): No data available.

8.2. Exposure controls

8.2.1. Appropriate engineering controls

: Provide adequate general and local exhaust ventilation

Systems under pressure should be regularily checked for leakages Ensure exposure is below occupational exposure limits (where available)

Keep concentrations well below lower explosion limits

Gas detectors should be used when flammable gases/vapours may be released

Consider work permit system e.g. for maintenance activities

8.2.2. Individual protection measures, e.g. personal protective equipment

: A risk assessment should be conducted and documented in each work area to assess the risks

related to the use of the product and to select the PPE that matches the relevant risk. The

following recommendations should be considered:

PPE compliant to the recommended EN/ISO standards should be selected

• Eye/face protection : Wear safety glasses with side shields

Standard EN 166 - Personal eye-protection

· Skin protection

- Hand protection : Wear working gloves when handling gas containers

Standard EN 388 - Protective gloves against mechanical risk

- Other : Consider the use of flame resistant anti-static safety clothing

Standard EN ISO 14116 - Limited flame spread materials

Standard EN ISO 1149-5 - Protective clothing: Electrostatic properties Wear safety shoes while handling containers

Standard EN ISO 20345 - Personal protective equipment - Safety footwear

• Respiratory protection : Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be

used in oxygen-deficient atmospheres

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask

• Thermal hazards : None necessary

8.2.3. Environmental exposure controls

: Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for specific methods for waste gas treatment.

SDS Ref.: AL702

SECTION 9: Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance

Physical state at 20°C / 101.3kPa : Gas.

EN (English)

5/9



SDS Ref.: AL702

Colour
 Mixture contains one or more component(s) which have the following colour(s):

Colourless.

Odour : There may be no odour warning properties, odour is subjective and inadequate to warn of

overexposure.

Mixture contains one or more component(s) which have the following odour(s):

Stenchant often added.

Odour threshold : Odour threshold is subjective and inadequate to warn of overexposure.

pH value : Not applicable for gas-mixtures.

Molar mass : Not applicable for gas-mixtures.

Melting point : Not applicable for gas-mixtures.

Boiling point : Not applicable for gas-mixtures.

Flash point : Not applicable for gas-mixtures.

Evaporation rate (ether=1) : Not applicable for gas-mixtures.

Flammability range : Flammability range not available.

Vapour pressure [20°C] : Not applicable.

Vapour pressure [50°C] : Not applicable.

Relative density, gas (air=1) : Lighter or similar to air.

Solubility in water : No data available

Partition coefficient n-octanol/water [log Kow] : Not applicable for gas-mixtures.

Auto-ignition temperature : Not known.

Viscosity [20°C] : Not applicable.

Explosive Properties : Not applicable

Oxidising Properties : Not applicable

9.2. Other information

Other data : None

SECTION 10: Stability and reactivity

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below

10.2. Chemical stability

: Stable under normal conditions

10.3. Possibility of hazardous reactions

: May react violently with oxidants Can form explosive mixture with air

10.4. Conditions to avoid

: Keep away from heat/sparks/open flames/hot surfaces. - No smoking

10.5. Incompatible materials

: None

10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be

produced

SECTION 11: Toxicological information

11.1. Information on toxicological effects

Acute toxicity : No toxicological effects from this product

Skin corrosion/irritation : No known effects from this product

EN (English)

SDS Ref.: AL702 6/9



SDS Ref.: AL702

Serious eye damage/irritation : No known effects from this product Respiratory or skin sensitisation : No known effects from this product Germ cell mutagenicity : No known effects from this product Carcinogenicity : No known effects from this product Toxic for reproduction : Fertility : No known effects from this product Toxic for reproduction: unborn child : No known effects from this product STOT-single exposure : No known effects from this product STOT-repeated exposure : No known effects from this product Aspiration hazard : Not applicable for gases and gas mixtures

SECTION 12: Ecological information

12.1. Toxicity

Assessment : Classification criteria are not met.

12.2. Persistence and degradability

Assessment : No data available.

12.3. Bioaccumulative potential

Assessment : No data available.

12.4. Mobility in soil

Assessment : No data available.

12.5. Results of PBT and vPvB assessment

Assessment : Not classified as PBT or vPvB

12.6. Other adverse effects

Effect on ozone layer : None

Effect on the global warming : Contains greenhouse gas(es) not covered by Regulation (EC) 842/2006.

SECTION 13: Disposal considerations

13.1. Waste treatment methods

Contact supplier if guidance is required

Do not discharge into areas where there is a risk of forming an explosive mixture with air.

Waste gas should be flared through a suitable burner with flash back arrestor Do not discharge into any place where its accumulation could be dangerous

Ensure that the emission levels from local regulations or operating permits are not exceeded

Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at

http://www.eiga.org for more guidance on suitable disposal methods

List of hazardous waste codes (from Commission Decision 2001/118/EC)

: 16 05 04: Gases in pressure containers (including halons) containing dangerous substances

13.2. Additional information

: None

SECTION 14: Transport information

14.1. UN number



SDS Ref.: AL702

UN-No. : 1954

14.2. UN proper shipping name

Transport by road/rail (ADR/RID) : COMPRESSED GAS, FLAMMABLE, N.O.S. (Methane, Nitrogen)

Transport by air (ICAO-TI / IATA-DGR) : Compressed gas, flammable, n.o.s. (Methane, Nitrogen)

Transport by sea (IMDG) : COMPRESSED GAS, FLAMMABLE, N.O.S. (Methane, Nitrogen)

14.3. Transport hazard class(es)

Labelling



2.1 : Flammable gases

Transport by road/rail (ADG)

Class : 2
Hazchemcode : 2SE
Hazard identification number : 23

Tunnel Restriction : B/D - Tank carriage : Passage forbidden through tunnels of category B, C, D and E. Other

carriage: Passage forbidden through tunnels of category D and E

Transport by air (ICAO-TI / IATA-DGR)

Class / Div. (Sub. risk(s)) : 2.1

Transport by sea (IMDG)

Class / Div. (Sub. risk(s)) : 2.1

Emergency Schedule (EmS) - Fire : F-D

Emergency Schedule (EmS) - Spillage : S-U

14.4. Packing group

Transport by road/rail (ADR/RID) : Not applicable
Transport by air (ICAO-TI / IATA-DGR) : Not applicable
Transport by sea (IMDG) : Not applicable

14.5. Environmental hazards

Transport by road/rail (ADR/RID) : None.

Transport by air (ICAO-TI / IATA-DGR) : None.

Transport by sea (IMDG) : None.

14.6. Special precautions for user

Packing Instruction(s)

Transport by road/rail (ADR/RID) : P200

Transport by air (ICAO-TI / IATA-DGR)

Passenger and Cargo Aircraft : Forbidden Cargo Aircraft only : 200
Transport by sea (IMDG) : P200

EN (English)

8/9

SDS Ref.: AL702



SDS Ref.: AL702

Special transport precautions

: Avoid transport on vehicles where the load space is not separated from the driver's

compartment

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the

event of an accident or an emergency Before transporting product containers: - Ensure there is adequate ventilation

- Ensure that containers are firmly secured - Ensure cylinder valve is closed and not leaking

- Ensure valve outlet cap nut or plug (where provided) is correctly fitted

- Ensure valve protection device (where provided) is correctly fitted.

HAZCHEMCODE : 2SE

Transport in bulk according to Annex II of MARPOL 73/78 and the IBC Code

: Not applicable.

SECTION 15: Regulatory information

<u>15.1.</u> Safety, health and environmental regulations/legislation specific for the substance or mixture

National regulations

Ensure all national/local regulations are observed.

Chemical safety assessment

: A CSA does not need to be carried out for this product

SECTION 16: Other information

Indication of changes : Revised safety data sheet in accordance with commission regulation (EU) No 453/2010.

Training advice : Ensure operators understand the flammability hazard. Receptacle under pressure.

Full text of H-statements

Flam. Gas 1	Flammable gases, Category 1
Ox. Gas 1	Oxidising Gases, Category 1
Press. Gas (Comp.)	Gases under pressure : Compressed gas
Press. Gas (Liq.)	Gases under pressure : Liquefied gas
H220	Extremely flammable gas
H270	May cause or intensify fire; oxidizer
H280	Contains gas under pressure; may explode if heated
R12	Extremely flammable
R8 Contact with combustible material may cause	
F+	Extremely flammable
0	Oxidising

DISCLAIMER OF LIABILITY

: Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out

Details given in this document are believed to be correct at the time of going to press Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted