

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723

Danger**SECTION 1. Identification of the substance/mixture and of the company/undertaking****1.1. Product identifier**

Trade name : 1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane
SDS Nr : AL723

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.
Test gas / Calibration gas. Laboratory use Contact supplier for more uses information

1.3. Details of the supplier of the safety data sheet

Company identification : Air Liquide Australia Limited
Level 9 / 380 St. Kilda Road
Melbourne VIC 3004 Australia
Tel: + 61 3 9697 9888
Fax: + 61 3 9690 7107
ALAEquiries@AirLiquide.com

1.4. Emergency telephone number

Emergency telephone number : 1800 812 588

SECTION 2. Hazards identification**2.1. Classification of the substance or mixture****Hazard Class and Category Code Regulation EC 1272/2008 (CLP)**

- Health hazards : Acute toxicity, Inhalation - Category 4 - Warning - (CLP : Acute Tox. 4) - H332
- Physical hazards : Flammable gases - Category 1 - Danger - (CLP : Flam. Gas 1) - H220
Gases under pressure - Compressed gas - Warning - (CLP : Press. Gas) - H280
- Environmental hazards : Hazardous to the aquatic environment - Chronic hazard - Category 3 - (CLP : Aquatic Chronic 3) - H412

Classification EC 67/548 or EC 1999/45

: F+; R12
T+; R26

2.2. Label elements**Labelling Regulation EC 1272/2008 (CLP)**

- Hazard pictograms



- Hazard pictograms code : GHS02 - GHS07 - GHS04
- Signal word : Danger
- Hazard statements : H220 - Extremely flammable gas.
H280 - Contains gas under pressure; may explode if heated.
H332 - Harmful if inhaled.
H412 - Harmful to aquatic life with long lasting effects.

- Precautionary statements

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723
SECTION 2. Hazards identification (continued)

- Prevention : P260 - Do not breathe gas, vapours.
P210 - Keep away from heat, sparks, open flames or hot surfaces. – No smoking.
P273 - Avoid release to the environment.
- Response : P304+P340+P315 - IF INHALED: Remove victim to fresh air and keep at rest in a position comfortable for breathing. Get immediate medical advice / attention.
P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely.
P381 - Eliminate all ignition sources if safe to do so.
- Storage : P403 - Store in a well-ventilated place.

2.3. Other hazards

: None.

SECTION 3. Composition/information on ingredients
3.1. Substance / 3.2. Mixture
Mixture.

Substance name	Contents	CAS No	EC No	Annex No		Classification
Butane n-	: Between 0.9 and 1.1 %	106-97-8	203-448-7	601-004-00-0	* 2	F+; R12 ----- Flam. Gas 1 (H220) Liq. Gas (H280)
Carbon dioxide	: Between 0.9 and 1.1 %	124-38-9	204-696-9	----	* 1	Not classified (DSD/DPD) ----- Liq. Gas (H280)
Ethane	: Between 0.9 and 1.1 %	74-84-0	200-814-8	601-002-00-X	* 2	F+; R12 ----- Flam. Gas 1 (H220) Press. Gas (H281)
Helium	: Between 0.9 and 1.1 %	7440-59-7	231-168-5	----	* 1	Not classified (DSD/DPD) ----- Press. Gas (H280)
n-hexane	: Between 0.2 and 2.5 %	110-54-3	203-777-6	601-037-00-0	----	F; R11 Repr. Cat. 3; R62 Xn; R65-48/20 R67 Xi; R38 N; R51-53 ----- Flam. Liq. 2 (H225) Asp. Tox 1 (H304) Repr. 2 (H361F) Skin Irrit. 2 (H315) STOT RE 2 (H373) STOT RE 3 (H336) Aquatic Chronic 2 5H411)
Hydrogen sulphide	: Between 1 and 25 %	7783-06-4	231-977-3	016-001-00-4	* 2	F+; R12 T+; R26 N; R50 ----- Flam. Gas 1 (H220) Acute Tox. 2 (H330) Liq. Gas (H280) Aquatic Acute 1 (H400)
Isobutane	: Between 0.9 and 1.1 %	75-28-5	200-857-2	601-004-00-0	* 2	F+; R12 ----- Flam. Gas 1 (H220) Liq. Gas (H280)
Isopentane	: Between 1 and 25 %	78-78-4	201-142-8	601-006-00-1	----	F+; R12 Xn; R65 R66 R67 N; R51-53 ----- Flam. Liq. 1 (H224) Asp. Tox 1 (H304) STOT RE 3 (H336) STOT RE (EUH066) Aquatic Chronic 2 5H411)
Nitrogen	: Between 0.9 and 1.1 %	7727-37-9	231-783-9	----	*1	Not classified (DSD/DPD) ----- Press. Gas (H280)
Oxygen	: Between 0.9 and 1.1 %	7782-44-7	231-956-9	008-001-00-8	* 1	O; R8 ----- Ox. Gas 1 (H270) Press. Gas (H280)



MATERIAL SAFETY DATA SHEET

Page : 3

Revised edition no : 0

Date : 16 / 1 / 2015

Supersedes : 0 / 0 / 0

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723

SECTION 3. Composition/information on ingredients (continued)

Substance name	Contents	CAS No	EC No	Annex No	Classification
n-Pentane	: Between 1 and 25 %	109-66-0	203-692-4	601-006-00-1	----- F+; R12 Xn; R65 R66 R67 N; R51-53 ----- Flam. Liq. 1 (H224) Asp. Tox 1 (H304) STOT RE 3 (H336) STOT RE (EUH066) Aquatic Chronic 2 (H411)
Propane	: Between 0.9 and 1.1 %	74-98-6	200-827-9	601-003-00-5	* 2 ----- F+; R12 ----- Flam. Gas 1 (H220) Liq. Gas (H280)
Methane	: Between 77.4 and 94.6 %	74-82-8	200-812-7	601-001-00-4	* 1 ----- F+; R12 ----- Flam. Gas 1 (H220) Press. Gas (H280)

Contains no other components or impurities which will influence the classification of the product.

* 1: Listed in Annex IV / V REACH, exempted from registration.

* 2: Registration deadline not expired.

* 3: Registration not required: Substance manufactured or imported < 1t/y

Full text of R-phrases see chapter 16. Full text of H-statements see chapter 16

SECTION 4. First aid measures

4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.
- Skin contact : Adverse effects not expected from this product.
- Eye contact : Adverse effects not expected from this product.
- Ingestion : Ingestion is not considered a potential route of exposure.

4.2. Most important symptoms and effects, both acute and delayed

- : In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/ consciousness. Victim may not be aware of asphyxiation. Refer to section 11.

4.3. Indication of any immediate medical attention and special treatment needed

- : Obtain medical assistance.

SECTION 5. Fire-fighting measures

5.1. Extinguishing media

- Suitable extinguishing media : All known extinguishants can be used.

5.2. Special hazards arising from the substance or mixture

- Specific hazards : Exposure to fire may cause containers to rupture/explode.
- Hazardous combustion products : Incomplete combustion may form carbon monoxide.

5.3. Advice for fire-fighters

- Specific methods : Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-ignition may occur. Extinguish any other fire. Coordinate fire measure to the surrounding fire. Cool endangered containers with water spray jet from a protected position. Do not empty contaminated fire water into drains. If possible, stop flow of product.
- Special protective equipment for fire fighters : Use self-contained breathing apparatus.

Air Liquide Australia Limited

Level 9 / 380 St. Kilda Road Melbourne VIC 3004 Australia

Tel: + 61 3 9697 9888

Fax: + 61 3 9690 7107

ALAEquiries@AirLiquide.com

In case of emergency : 1800 812 588

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 6. Accidental release measures****6.1. Personal precautions, protective equipment and emergency procedures**

- : Evacuate area.
- Wear self-contained breathing apparatus when entering area unless atmosphere is proved to be safe.
- Try to stop release.
- Monitor concentration of released product.
- Ensure adequate air ventilation.
- Eliminate ignition sources.
- Consider the risk of potentially explosive atmospheres.

6.2. Environmental precautions

- : Try to stop release.

6.3. Methods and material for containment and cleaning up

- : Ventilate area.

6.4. Reference to other sections

- : See also sections 8 and 13.

SECTION 7. Handling and storage**7.1. Precautions for safe handling****Safe use of the product**

- : Avoid exposure, obtain special instructions before use.
- Take precautionary measures against static discharge.
- Purge air from system before introducing gas.
- Keep away from ignition sources (including static discharges).
- Do not smoke while handling product.
- Assess the risk of potentially explosive atmosphere and the need for explosion-proof equipment.
- Consider the use only non-sparking tools.
- Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt.
- Only experienced and properly instructed persons should handle gases under pressure.
- The product must be handled in accordance with good industrial hygiene and safety procedures.
- Ensure the complete gas system was (or is regularly) checked for leaks before use.

Safe handling of the gas receptacle

- : Refer to supplier's container handling instructions.
- Do not allow backfeed into the container.
- Protect cylinders from physical damage; do not drag, roll, slide or drop.
- When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.
- Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use.
- If user experiences any difficulty operating cylinder valve discontinue use and contact supplier.
- Never attempt to repair or modify container valves or safety relief devices.
- Damaged valves should be reported immediately to the supplier.
- Keep container valve outlets clean and free from contaminants particularly oil and water.
- Replace valve outlet caps or plugs and container caps where supplied as soon as container is disconnected from equipment.
- Close container valve after each use and when empty, even if still connected to equipment.
- Never attempt to transfer gases from one cylinder/container to another.
- Never use direct flame or electrical heating devices to raise the pressure of a container.
- Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.

7.2. Conditions for safe storage, including any incompatibilities

- : Segregate from oxidant gases and other oxidants in store.
- All electrical equipment in the storage areas should be compatible with the risk of potentially explosive atmosphere.
- Keep away from combustible materials.
- Keep container below 50°C in a well ventilated place.
- Observe all regulations and local requirements regarding storage of containers.

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 7. Handling and storage (continued)**

Containers should not be stored in conditions likely to encourage corrosion.
Containers should be stored in the vertical position and properly secured to prevent toppling.
Stored containers should be periodically checked for general condition and leakage.
Container valve guards or caps should be in place.
Store containers in location free from fire risk and away from sources of heat and ignition.

7.3. Specific end use(s)

: None.

SECTION 8. Exposure controls/personal protection**8.1. Control parameters****Occupational Exposure Limits****Butane n-**

: MAK (AU) Tagesmittelwert (ml/m³) : 800
: MAK (AU) Tagesmittelwert (mg/m³) : 1900
: MAK (AU) Kurzzeitwerte (mg/m³) : 3800
: MAK (AU) Kurzzeitwerte (ml/m³) : 1600
: TLV[®] -TWA [ppm] : 800
: LTEL - UK [ppm] : 600
: STEL - UK [mg/m³] : 750
: VME - France [mg/m³] : 1900
: VME - France [ppm] : 800
: AGW (8h) - Germany [mg/m³] TRGS 900 : 2400
: AGW (8h) - Germany [ppm] TRGS 900 : 1000
: Exceeding factor AGW - Germany TRGS 900 : 4
: VLA-ED - Spain [ppm] : 1000
: Grænserværdier (DK) (ppm) : 500
: HTP-vården (FI) - 8 H - [ppm] : 800
: HTP-vården (FI) - 8 H - [mg/m³] : 1900
: HTP-vården - 15min - [ppm] : 1000
: Grænserværdier (DK) : 1200
: HTP-vården - 15min - [mg/m³] : 2400
: GV Value Limit (Norway) [ppm] : 250
: GV Value Limit (Norway) [mg/m³] : 600
: TLV-TWA (Belgium) (ppm) : 800

n-hexane

: MAK (AU) Tagesmittelwert (ml/m³) : 50
: MAK (AU) Tagesmittelwert (mg/m³) : 180
: MAK (AU) Kurzzeitwerte (mg/m³) : 720
: MAK (AU) Kurzzeitwerte (ml/m³) : 200
: Tentativ Grænserværdi (DK) (ppm) : 144
: Grænserværdier (DK) (ppm) : 72
: ILV (EU) - 8 H - [mg/m³] : 72
: ILV (EU) - 8 H - [ppm] : 20
: TLV[®] -TWA [ppm] : 50
: LTEL - UK [mg/m³] : 72
: LTEL - UK [ppm] : 20
: VME - France [mg/m³] : 170
: VME - France [ppm] : 50
: AGW (8h) - Germany [mg/m³] TRGS 900 : 180
: AGW (8h) - Germany [ppm] TRGS 900 : 50
: Exceeding factor AGW - Germany TRGS 900 : 8

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723
SECTION 8. Exposure controls/personal protection (continued)

	: VLA-ED - Spain [ppm] : 50 : VLA-ED - Spain [mg/m ³] : 179 : NGV - [ppm] : 25 : NGV - [mg/m ³] : 90 : KTV - [ppm] : 50 : KTV - [mg/m ³] : 50 : Grænserværdier (DK) (ppm) : 25 : HTP-värden (FI) - 8 H - [ppm] : 20 : HTP-värden (FI) - 8 H - [mg/m ³] : 72 : Grænserværdier (DK) : 90 : GV Value Limit (Norway) [ppm] : 25 : GV Value Limit (Norway) [mg/m ³] : 90 : 8-Hour TWA (PL) (NDS) (mg/m ³) : 72 : TLV-TWA (Belgium) (ppm) : 50
Propane	: MAK (AU) Tagesmittelwert (ml/m ³) : 1000 : MAK (AU) Kurzzeitwerte (mg/m ³) : 3600 : MAK (AU) Tagesmittelwert (mg/m ³) : 1800 : MAK (AU) Kurzzeitwerte (ml/m ³) : 2000 : TLV© -TWA [ppm] : 2500 : AGW (8h) - Germany [mg/m ³] TRGS 900 : 1000 : AGW (8h) - Germany [ppm] TRGS 900 : 1800 : Exceeding factor AGW - Germany TRGS 900 : 4 : VLA-ED - Spain [ppm] : 1000 : Grænserværdier (DK) (ppm) : 1000 : HTP-värden (FI) - 8 H - [ppm] : 800 : HTP-värden (FI) - 8 H - [mg/m ³] : 1500 : HTP-värden - 15min - [ppm] : 1100 : Grænserværdier (DK) : 1800 : HTP-värden - 15min - [mg/m ³] : 2000 : GV Value Limit (Norway) [ppm] : 500 : GV Value Limit (Norway) [mg/m ³] : 900 : 8-Hour TWA (PL) (NDS) (mg/m ³) : 1800
Isobutane	: LTEL - UK [ppm] : 500 : STEL - UK [ppm] : 750 : MAK (AU) Tagesmittelwert (ml/m ³) : 800 : MAK (AU) Tagesmittelwert (mg/m ³) : 1900 : MAK (AU) Kurzzeitwerte (mg/m ³) : 3800 : MAK (AU) Kurzzeitwerte (ml/m ³) : 1600 : TLV© -TWA [ppm] : 800 : AGW (8h) - Germany [mg/m ³] TRGS 900 : 2400 : AGW (8h) - Germany [ppm] TRGS 900 : 1000 : Exceeding factor AGW - Germany TRGS 900 : 4 : HTP-värden (FI) - 8 H - [ppm] : 800 : HTP-värden (FI) - 8 H - [mg/m ³] : 1900 : HTP-värden - 15min - [ppm] : 1000 : HTP-värden - 15min - [mg/m ³] : 2400
Hydrogen sulphide	: Value 8h (CZ) [mg/m ³] : 10 : ILV (EU) - 8 H - [mg/m ³] : 7 : ILV (EU) - 8 H - [ppm] : 5

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 8. Exposure controls/personal protection (continued)**

: ILV (EU) - 15 min - [mg/m³] : 14
: ILV (EU) - 15 min - [ppm] : 10
: TLV[©]-TWA [ppm] : 5
: LTEL - UK [ppm] : 10
: VLE - France [mg/m³] : 14
: VLE - France [ppm] : 10
: VME - France [mg/m³] : 7
: VME - France [ppm] : 5
: AGW (8h) - Germany [mg/m³] TRGS 900 : 10
: AGW (8h) - Germany [ppm] TRGS 900 : 14
: Exceeding factor AGW - Germany TRGS 900 : 1
: MAK (AU) Tagesmittelwert (ml/m³) : 10
: MAK (AU) Tagesmittelwert (mg/m³) : 15
: MAK (AU) Kurzzeitwerte (ml/m³) : 10
: MAK (AU) Kurzzeitwerte (mg/m³) : 15
: VLA-ED - Spain [ppm] : 10
: VLA-ED - Spain [mg/m³] : 14
: VLA-EC - Spain [ppm] : 15
: VLA-EC - Spain [mg/m³] : 21
: NGV - [ppm] : 10
: NGV - [mg/m³] : 14
: TGV - [mg/m³] : 20
: TGV - [ppm] : 15
: HTP-värden (FI) - 8 H - [ppm] : 10
: HTP-värden (FI) - 8 H - [mg/m³] : 14
: Grænserværdier (DK) (ppm) : 15
: Grænserværdier (DK) (ppm) : 10
: Grænserværdier (DK) : 15
: HTP-värden - 15min - [ppm] : 15
: HTP-värden - 15min - [mg/m³] : 21
: GV Value Limit (Norway) [ppm] : 10
: GV Value Limit (Norway) [mg/m³] : 15
: 8-Hour TWA (PL) (NDS) (mg/m³) : 10
: 15-Minute STEL (PL)(NDSch) (mg/m³) : 20
: Value 15min. (CZ) [mg/m³] : 20
: Value 8h (CZ) [mg/m³] : 9000
: ILV (EU) - 8 H - [mg/m³] : 9000
: ILV (EU) - 8 H - [ppm] : 5000
: TLV[©]-TWA [ppm] : 5000
: TLV[©]-STEL [ppm] : 30000
: AGW (8h) - Germany [mg/m³] TRGS 900 : 9100
: AGW (8h) - Germany [ppm] TRGS 900 : 5000
: MAK (AU) Tagesmittelwert (ml/m³) : 5000
: MAK (AU) Tagesmittelwert (mg/m³) : 9000
: MAK (AU) Kurzzeitwerte (ml/m³) : 10000
: MAK (AU) Kurzzeitwerte (mg/m³) : 18000
: VLA-ED - Spain [ppm] : 5000
: VLA-ED - Spain [mg/m³] : 9150
: VLA-EC - Spain [ppm] : 15000

Carbon dioxide

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723
SECTION 8. Exposure controls/personal protection (continued)

: VLA-EC - Spain [mg/m³] : 27400
 : NGV - [ppm] : 5000
 : NGV - [mg/m³] : 9000
 : KTV - [ppm] : 10
 : KTV - [mg/m³] : 10
 : HTP-värden (FI) - 8 H - [ppm] : 5000
 : HTP-värden (FI) - 8 H - [mg/m³] : 9100
 : Grænserværdier (DK) (ppm) : 9000
 : Grænserværdier (DK) (ppm) : 5000
 : Grænserværdier (DK) : 9000
 : GV Value Limit (Norway) [ppm] : 5000
 : GV Value Limit (Norway) [mg/m³] : 9000
 : 8-Hour TWA (PL) (NDS) (mg/m³) : 9000
 : 15-Minute STEL (PL)(NDSch) (mg/m³) : 27000
 : Valori Limite di Soglia (IT) 8 ore [ppm] : 5000
 : Valori Limite di Soglia (IT) 8 ore [mg/m³] : 9000
 : TLV-TWA (Belgium) (ppm) : 5000
 : TLV-STEL (Belgium) (ppm) : 30000
 : Value 15min. (CZ) [mg/m³] : 45000
 : None available.
 : None available.

DNEL: Derived no effect level
PNEC: Predicted no effect concentration

8.2. Exposure controls
8.2.1. Appropriate engineering controls

: Product to be handled in a closed system.
 Alarm detectors should be used when toxic gases may be released.
 Ensure exposure is below occupational exposure limits (where available).
 Provide adequate general and local exhaust ventilation.
 Systems under pressure should be regularly checked for leakages.
 Keep concentrations well below lower explosion limits.
 Consider work permit system e.g. for maintenance activities.

8.2.2. Individual protection measures, e.g. personal protective equipment

: A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.
 The following recommendations should be considered.
 Wear leather safety gloves and safety shoes when handling cylinders.
 Wear safety glasses with side shields
 Keep self contained breathing apparatus readily available for emergency use.
 Consider the use of flame resistant anti-static safety clothing.

8.2.3. Environmental exposure controls

: Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for specific methods for waste gas treatment.

SECTION 9. Physical and chemical properties
9.1. Information on basic physical and chemical properties
Appearance

- Physical state at 20°C / 101.3kPa : Gas.
 - Colour : Colourless gas.
 Odour : Rotten eggs.
 Odour threshold : Odour threshold is subjective and inadequate to warn for overexposure.
 pH value : Not applicable for gas-mixtures.
 Molar mass [g/mol] : Not applicable for gases and gas-mixtures.
 Melting point [°C] : Not applicable for gas-mixtures.
 Boiling point [°C] : Not applicable for gas-mixtures.

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 9. Physical and chemical properties (continued)**

Flash point [°C]	: Not applicable for gas-mixtures.
Evaporation rate (ether=1)	: Not applicable for gas-mixtures.
Flammability range [vol% in air]	: Not applicable for gas-mixtures.
Vapour pressure [20°C]	: Not applicable.
Relative density, gas (air=1)	: Lighter or similar to air.
Solubility in water [mg/l]	: Not known, but considered to have low solubility.
Partition coefficient n-octanol/water	: Not applicable for gas-mixtures.
Viscosity at 20°C [mPa.s]	: Not applicable.
Explosive Properties	: Not applicable.

9.2. Other information

Other data : None.

SECTION 10. Stability and reactivity**10.1. Reactivity**

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions

: May react violently with oxidants.
Can form explosive mixture with air.

10.4. Conditions to avoid

: Keep away from heat/sparks/open flames/hot surfaces. – No smoking.

10.5. Incompatible materials

: Not compatible with the following materials: oxidizing agents, organic peroxides, alkaline materials, metals and metal oxides.

10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be produced.

SECTION 11. Toxicological information**11.1. Information on toxicological effects**

Acute toxicity	: Harmful if inhaled.
Rat inhalation LC50 [ppm/4h]	: • Hydrogen sulphide : 356
Skin corrosion/irritation	: No known effects from this product.
Serious eye damage/irritation	: No known effects from this product.
Respiratory or skin sensitisation	: No known effects from this product.
Carcinogenicity	: No known effects from this product.
Germ cell mutagenicity	: No known effects from this product.
Toxic for reproduction : Fertility	: No known effects from this product.
Toxic for reproduction : unborn child	: No known effects from this product.
STOT-single exposure	: No known effects from this product.
STOT-repeated exposure	: No known effects from this product.
Aspiration hazard	: Not applicable for gases and gas-mixtures.

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 12. Ecological information****12.1. Toxicity**

: Harmful to aquatic life with long lasting effects.

12.2. Persistence - degradability

: No data available.

12.3. Bioaccumulative potential

: No data available.

12.4. Mobility in soil

: No data available.

12.5. Results of PBT and vPvB assessment

: No data available.

12.6. Other adverse effects

Effect on ozone layer

: None.

Effect on the global warming

: Contains greenhouse gas(es) not covered by 842/2006/EC

SECTION 13. Disposal considerations**13.1. Waste treatment methods**

: Avoid discharge to atmosphere.
Do not discharge into any place where its accumulation could be dangerous.
Ensure that the emission levels from local regulations or operating permits are not exceeded.

Refer to the code of practice of EIGA (Doc. 30/10 "Disposal of Gases, downloadable at <http://www.eiga.org>) for more guidance on suitable disposal methods
Do not discharge into areas where there is a risk of forming an explosive mixture with air.
Waste gas should be flared through a suitable burner with flash back arrestor.
Contact supplier if guidance is required.

13.2. Additional information

: None.

SECTION 14. Transport information

UN number

: 1954

Labelling ADR, IMDG, IATA



: 2.1 : flammable gas.

Land transport (ADR/RID)

H.I. nr

: 23

UN proper shipping name

: COMPRESSED GAS, FLAMMABLE, N.O.S. (Methane, Hydrogen sulphide)

Transport hazard class(es)

: 2

Classification code

: 1 F

Packing Instruction(s)

: P200

Tunnel Restriction

: B/D Tank carriage: Passage forbidden through tunnels of category B, C, D

HAZCHEM - Emergency Action Code

: 2SE

2 = Fine water spray.

S = Risk of violent reaction or explosion. Recommended personal protective equipment : Full fire kit and breathing apparatus. Appropriate measures : dilute.

E = There may be a public safety hazard outside the immediate area of the incident, and that the following actions should be considered :

1. People should be warned to stay indoors with all doors and windows closed, preferably in

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 14. Transport information (continued)**

rooms upstairs and facing away from the incident. Ignition sources should be eliminated and any ventilation stopped.

2. Effects may spread beyond the immediate vicinity. all non-essential personnel should be instructed to move at least 250 metres away from the incident.
3. Police and fire brigade incident commanders should consult each other and with a product expert, or with a source of product expertise.
4. The possible need for subsequent evacuation should be considered, but it should be remembered that in most cases it will be safer to remain in a building than to evacuate.

Sea transport (IMDG)

Proper shipping name : COMPRESSED GAS, FLAMMABLE, N.O.S. (Methane, Hydrogen sulphide)
Class : 2.1
Emergency Schedule (EmS) - Fire : F-D
Emergency Schedule (EmS) - Spillage : S-U
Packing instruction : P200

Air transport (ICAO-TI / IATA-DGR)

Proper shipping name (IATA) : COMPRESSED GAS, FLAMMABLE, N.O.S. (Methane, Hydrogen sulphide)
Class : 2.1
Passenger and Cargo Aircraft : DO NOT LOAD IN PASSENGER AIRCRAFT.
Cargo Aircraft only : Allowed.
Packing instruction - Cargo Aircraft only : 200

Special precautions for user

: Avoid transport on vehicles where the load space is not separated from the driver's compartment.
Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.
Before transporting product containers :
- Ensure there is adequate ventilation.
- Ensure that containers are firmly secured.
- Ensure cylinder valve is closed and not leaking.
- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.
- Ensure valve protection device (where provided) is correctly fitted.

SECTION 15. Regulatory information**15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture****EU legislation**

Seveso directive 96/82/EC : Covered

National legislation

: Ensure all national/local regulations are observed.

15.2. Chemical Safety Assessment

: A CSA does not need to be carried out for this product.

1% n-Butane, 1% CO₂, 1% Ethane, 1% Helium, 1% Hexane, 3% H₂S, 1% iso-Butane, 1% iso-Pentane , 1% N₂, 1% O₂, 1% n-Pentane, 1% Propane in Methane

AL723**SECTION 16. Other information**

- Indication of changes** : Revised safety data sheet in accordance with commission regulation (EU) No 453/2010
- Training advice** : Users of breathing apparatus must be trained.
Ensure operators understand the flammability hazard.
Receptacle under pressure.
- List of full text of R-phrases in section 3.** : R8 : Contact with combustible material may cause fire.
R11 : Highly flammable.
R12 : Extremely flammable.
R26 : Very toxic by inhalation.
R38 : Irritating to skin.
R48/20 : Harmful : danger of serious damage to health by prolonged exposure through inhalation.
R50 : Very toxic to aquatic organisms.
R51/53 : Toxic to aquatic organisms, may cause long-term adverse effects in the aquatic environment.
R62 : Possible risk of impaired fertility.
R65 : Harmful : may cause lung damage if swallowed.
R66 : Repeated exposure may cause skin dryness or cracking.
R67 : Vapours may cause drowsiness and dizziness.
- List of full text of H-statements in section 3.** : EUH066 - Repeated exposure may cause skin dryness or cracking.
H220 - Extremely flammable gas.
H224 - Extremely flammable liquid and vapour.
H225 - Highly flammable liquid and vapour.
H270 - May cause or intensify fire; oxidizer.
H280 - Contains gas under pressure; may explode if heated.
H281 - Contains refrigerated gas; may cause cryogenic burns or injury.
H304 - May be fatal if swallowed and enters airways.
H315 - Causes skin irritation.
H330 - Fatal if inhaled.
H336 - May cause drowsiness or dizziness.
H361F - Suspected of damaging fertility.
H373 - May cause damage to organs through prolonged or repeated exposure.
H400 - Very toxic to aquatic life.
H411 - Toxic to aquatic life with long lasting effects.
- Further information** : Classification in accordance with calculation methods of regulation (EC) 1272/2008 CLP / (EC) 1999/45 DPD.
This Safety Data Sheet has been established in accordance with the applicable European Union legislation.
- DISCLAIMER OF LIABILITY** : Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.
Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

The contents and format of this SDS are in accordance with EC Commission Directive 2001/58/EC.

DISCLAIMER OF LIABILITY The information in this SDS was obtained from sources which we believe are reliable. However, the information is provided without any warranty, express or implied, regarding its correctness. The conditions or methods of handling, storage, use or disposal of the product are beyond our control and may be beyond our knowledge. For this and other reasons, we do not assume responsibility and expressly disclaim liability for loss, damage or expense arising out of or in any way connected with the handling, storage, use or disposal of the product. This MSDS was prepared and is to be used only for this product. If the product is used as a component in another product, this MSDS information may not be applicable.

End of document